

THE CITY OF WINNIPEG

BY LAW NO. 4958/88

A By-law of THE CITY OF WINNIPEG to amend the Residential Buildings Fire Safety By-law No. 4304/86.

THE CITY OF WINNIPEG, in Council assembled, enacts as follows:

By-law No. 4304/86 of The City of Winnipeg, as amended by By-law No. 4742/87, is hereby further amended as follows:

1. By-law No. 4304/86 is hereby amended by deleting Section 7 thereof and substituting therefor the following:

"7. The Supervisor of Building Inspections may in special cases that in the Supervisor's discretion warrant it:

(a) modify or vary any special requirement where he is satisfied in his discretion that such modification or variation will substantially accomplish the object of the requirement; and

(b) grant an extension of the time up to five (5) months for completing the upgrading work from the date of the owner's application, where he is satisfied with the way the work will progress."

2. B.2.4 of Schedule "B" to By-law No. 4304/86 is hereby amended by adding immediately at the end thereof, the following:

"B.2.4(10) A heat detector shall be located on the ceiling of a hallway or other room open to the remainder of the suite, in all suites that open directly to the exterior and have no direct access to an interior public corridor or exit stairway."

3. F.4.1 of Schedule "F" to By-law No. 4304/86 is hereby amended by adding immediately at the end thereof, the following:

"F.4.1(4) In every building each elevator shall be provided with additional means to cancel all calls and immediately return the elevator to the street floor upon activation of any alarm initiating device of the building fire alarm system."


DONE AND PASSED, in Council assembled, this 14th day of Sept. A.D. 1988.

(SEAL)


(Sgd.) William Norrie
Mayor

(Sgd.) R. B. Hayes
City Clerk

Certified as to planning
details:


for Director of Environmental
Planning

Certified as to form:


for City Solicitor