APPENDIX B

REPORT OF THE ADMINISTRATIVE COORDINATING GROUP

RE: PROPOSED SUBDIVISION AND REZONING OF LAND LOCATED AT 201 LEILA AVENUE

The Administrative Coordinating Group (ACG) reviewed the servicing requirements for DASZ 25/2025. The applicant should take into consideration the following servicing and design requirements and considerations in the redevelopment of the site:

Section I – Plan Considerations

The Developer shall, at no expense to the City, transfer to the City and legally open, property as right-of-way, as shown on Appendix C- Property Requirement Drawing "PR24-05-A-1.00" dated 2024-11-12, to the satisfaction of the Director of Public Works.

Section I – General Comments

1. The Water and Waste Department (WWD) advises that there is adequate water servicing for the proposed development based on the provided development plans. In the event that the development plans change, WWD will need to review the revised proposal.

2. The subject land is located in a combined sewer district. According to Clause 8 of Environment Act Licence 3042, any development on the land cannot increase the flow into the combined sewer. Typically, increases in wastewater discharge can be offset by a reduction in land drainage discharge from the property.

   When the development proposal proceeds to the site servicing design stage; the sum of the wastewater and land drainage runoff peak discharge from the proposed future development into the combined sewer cannot exceed the allowable discharge rate:

   a) The allowable discharge rate will be the sum of the existing peak wastewater and the peak land drainage discharged.

   b) The peak land drainage discharged from the site must be based on a c-value of 0.35, with a 5-year rainfall event applied.

   c) The existing and proposed peak wastewater discharge must be estimated using the Wastewater Flow Estimation guidelines found on the City of Winnipeg website (http://winnipeg.ca/waterandwaste/dept/wastewaterFlow.stm), unless otherwise approved.

THIS REPORT SUBMITTED BY:

Administrative Co-ordinating Group
File No. DASZ 25/2025
Sept 22, 2025

"*Original Signed by K. Kowalyk"*
K. Kowalyk, P. Eng.
Land Development Branch
Planning, Property and Development Department

"*Original Signed by M. Gajda"*
M. Gajda, P. Eng.
Engineering Division
Water and Waste Department

"*Original Signed by C. Desjardine"*
C. Desjardine, M. Sc., P. Eng.
Transportation Division
Public Works Department